

**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIVISIONAL FIRE OFFICER  
WEST BENGAL FIRE & EMERGENCY SERVICES  
Bhangakuthi, G.T. Road, Burdwan - 4**

Memo No : IND/WB/FES/20192020/63106

DATE: 05/08/2019

**From :**

**The Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services.**

**To :**

**SWAMI VIVEKANANDA ACADEMY FOR EDUCATIONAL EXCELLENCE G T ROAD  
KANAINATSHAL PO SRIPALLY  
PLOT NO :- 550 , 543,543/793,J.L NO :- 76  
, KHATIAN NO :- 3356 , MOUZA :-  
KANAINATSHAL , PS :- BARDHAMAN  
SADAR , DIST :- PURBA BARDHAMAN  
Burdwan F.S., Bardhaman PS,  
Purba Bardhaman - 713101 .**

**Sub :Renewal of Fire Safety Certificate for occupancy of an existing construction of  
Lower Ground + Ground + 3 Storied educational building in favour of SWAMI  
VIVEKANANDA ACADEMY FOR EDUCATIONAL EXCELLENCE , Unit of Dr.Patras'  
Educational Trust , over G.T.ROAD,KANAINATSHAL,PO:- SRIPALLY , PLOT NO :- 550 ,  
543,543/793,J.L NO :- 76 , KHATIAN NO :- 3356 , MOUZA :- KANAINATSHAL , PS :-  
BARDHAMAN SADAR , DIST :- PURBA BARDHAMAN for issuance of Renewal of Fire  
Safety Certificate against Online Application No : IND/WB/FES/20192020/63106**

This is in reference to your Application No. IND/WB/FES/20192020/63106,dated 05/08/2019,  
regarding the Renewal of Fire Safety Certificate for occupancy of an existing construction of  
Lower Ground + Ground + 3 Storied educational building in favour of SWAMI  
VIVEKANANDA ACADEMY FOR EDUCATIONAL EXCELLENCE , Unit of Dr.Patras'  
Educational Trust , over G.T.ROAD,KANAINATSHAL,PO:- SRIPALLY , PLOT NO :- 550 ,  
543,543/793,J.L NO :- 76 , KHATIAN NO :- 3356 , MOUZA :- KANAINATSHAL , PS :-  
BARDHAMAN SADAR , DIST :- PURBA BARDHAMAN for issuance of Renewal of Fire  
Safety Certificate against Online Application No : IND/WB/FES/20192020/63106.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. This is in reference to your Application No. IND/WB/FES/20192020/63106 , dated 01.08.2019 ,regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of Lower Ground + Ground + 3 Storied educational building in favour of SWAMI VIVEKANANDA ACADEMY FOR EDUCATIONAL EXCELLENCE , Unit of Dr.Patras' Educational Trust , over G.T.ROAD,KANAINATSHAL,PO:- SRIPALLY , PLOT NO :- 550 , 543,543/793,J.L NO :- 76 , KHATIAN NO :- 3356 , MOUZA :- KANAINATSHAL , PS :- BARDHAMAN SADAR , DIST :- PURBA BARDHAMAN.

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for three years As per existing Govt. Notification of the aforesaid building.

#### CONDITION APPLIED

- 1.Maintenance/checking /testing of all fire safety installations shall be checked time to time.
- 2.Any nominated officer of this Deptt. Shall enter and inspect the building at any time between sunrise to sunset for ascertaining the contravention if any of Fire prevention and fire safety measures.
- 3.Good house keeping should be always to be maintained.
- 4.Mock fire and evacuation drill shall be conducted at an interval of every 4 months and to be recorded in a separate register.
- 5.To up-keep the Fire Safety Measures of the aforesaid building the following safety
- 6.measures are to be incorporated.
- 7.Driveway must be free of any type of obstruction for easy movement of Fire Appliances.
- 8.No parking will be allowed on the Driveway.
- 9.The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
- 10.To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
- 11.The employees and security staffs shall be conversant with installed Fire Fighting
- 12.Equipments of the building and to operate in the event of Fire and Testing.
- 13.Mock Fire practice and Evacuation Drill shall be performed periodically with participants of



all the occupants of the building.

14. First-Aid Fire Fighting system shall be provided as per I.S. specification.

15. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.

16. Another stair case shall be made positively.

17. No inflammable liquids and combustible substances shall be stored in the building except the quantity required for normal occupancy.

18. The electrical installations and fitting/fixtures etc shall strictly be in accordance with the I.S 1646 standard.

19. The building shall be protected with 4 nos of co2 (Each 4.5 kgs) fire extinguisher.

20. In case of any land dispute /building dispute /Litigation between landlord and tenants /court case etc if arises any time this department has no liabilities and responsibilities in this matter.

21. Violation of any recommendations which issued from this office previously this fire safety certificate shall be treated as cancelled and no renewal would be made.

22. This N.O.C. is valid for 3(Three) years from the date of issue of this letter.

Note :- This certificate is computer generated with digital signature and does not require any seal in original. The authenticity of this certificate can be verified at <https://eservices.wb.gov.in> (Third Party verification report)

**Divisional Fire Officer**  
**West Bengal Fire & Emergency Services**

Signature valid

Digitally signed by NITAI  
CHATTOPADHYAY  
Date: 2019.08.05 14:11:11 IST