

**BUILDING SAFETY CERTIFICATE**

No. BDA/09764.

Dated: 18/06/2018

Certified that the School Building on L.R. Plot.no. 543(Part), 543/793, 550(part), J.L.No.-76, Khatian no 3356, Mouza-Kanainatsal, P.S. Burdwan, Dist-Burdwan under Baikunthapur-II Gram Panchayet within Burdwan Development Authority at Kanainatsal, G.T.Road, Burdwan-713103 comprised of 1(one) basement and 1(one) Ground Floor and 3(three upper floors) owned/occupied by SWAMI VIVEKANANDA ACADEMY FOR EDUCATIONAL EXCELLENCE, BURDWAN have complied with the Building Bye Laws in accordance with rule of State/UT, and incorporate the provisions of building safety as specified in National Building Code 2005, 2016 and as amended thereafter and has been verified by the concerned officer on 06/05/2016 in the presence of Dr. Gouri Patra(Manager, Swami Vivekananda Academy for Educational Excellence, Kanainatsal,G.T.Road, P.O. Sripally, Dist-Burdwan, Pin-713103) and that the said above building/premises is safe and fit for running School with effect from 15/05/2016 for a period of 30 years and beyond in accordance with rules.


Signature with Seal:

*H. J. Choudhary* 18/6/18  
Assistant Engineer  
Burdwan Development Authority  
Burdwan

To

**Manager/Principal,****SWAMI VIVEKANANDA ACADEMY FOR EDUCATIONAL EXCELLENCE, BURDWAN,  
Kanainatsal, G.T.Road, P.O. Sripally, Burdwan-713103.****Swami Vivekananda Academy  
For  
Educational Excellence**

*Saganha Patra*  
**Manager**


  
**Principal  
Swami Vivekananda Academy  
For  
Educational Excellence**

Condition Applied :-

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. Entrance / Exits as marked in the sanctioned plan drawing must be opened and free from any type of obstruction.
3. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
5. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
6. No inflammable articles shall be stored inside the store room.
7. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
8. The employees and security staffs shall be conversant with installed fire fighting equipments of the building and to operate in the event of fire and testing.
9. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
10. Transformer, switch gear, main & meter room shall be protected with CO2 or DCP Fire extinguishers confirming I.S. specifications.
11. A crew of trained Firemen under an experienced officer shall be maintained round the clock for fire safety of the building.
12. First Aid fire fighting system shall be provided as per I.S. specifications.
13. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
14. If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
15. All pumps and detection system which are incorporated in the building shall be kept in auto mode round the clock.
16. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
17. Emergency lighting system (Battery Backup) to be installed in the staircase for the safe evacuation.
18. Electrical audit shall be conducted in every year and a certificate must be submitted in this office at the time of renewal of fire safety certificate.
19. This Renewal of Fire Safety Certificate is valid for 3 years as per existing Govt. Rule and has to be renewed as per existing Govt. Rule from the date of issue of this letter.

Signature valid

Digitally signed by Shyam  
Chandra Mondal  
Date: 2022.11.02 16:33:27 IST



Principal  
Swami Vivekananda Academy  
For  
Educational Excellence

Swami Vivekananda Academy  
For  
Educational Excellence  
Saganika Patra  
Manager

Divisional Fire Officer, Purba Bardhaman  
West Bengal Fire & Emergency Services