

GOVERNMENT OF WEST BENGAL
 SAKTIGARH SUB DISTRICT WATER TESTING LABORATORY
 WATER AND SANITATION SECTION
 PUBLIC HEALTH ENGINEERING DIRECTORATE
 SAKTIGARH, BURDWAN - II, PURBA BARDHAMAN.
**WATER SAMPLE TEST REPORT OF SWAMI VIVEKANANDA ACADEMY FOR
 EDUCATIONAL EXCELLENCE :-JULY -2024**

PANCHAYET SAMITTEE:- BURDWAN-II PANCHAYET:-BAIKUNTHAPUR-II.BOOK NO-8305/84.

| SL NO | VILLAGE | HABITATION | LOCATION | DATE | CHEMICAL | | | | | | | BACTERIOLOGICAL | |
|----------|-------------|-------------|-------------|-----------|----------|--------------------|-------------------|-------|------|------|--------------|-----------------|-----|
| | | | | | PH | RESI DUA LCL | TUR BIDI TY | TDS | IRON | Mn | HARDN ESS | T.C. | F.C |
| 1 | KANAINATSAL | KANAINATSAL | MAIN SOURCE | 3.07.2024 | 7.03 | 0.2 | 0.31 | 288.5 | 0.12 | 0.02 | 197.5 | 0 | 0 |

Desirable Limit:- pH - 6.5 to 8.5, Turbidity - <5, Hardness:- 300 to 600 mg/lit,
 Iron:- 1 mg/lit, Mn - 0.3 mg/lit, Bacteriological Safe:- T.C-0, F.C. Must be - 0.

Date:- 03.07.24

Kaishor
 CHEMIST
 03.07.24

Sankar
 BACTERIOLOGIST
 03/7/24

